

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:40 pm

PWS ID: UTAH22084 **Name:** UINTALANDS ASSOCIATION
Legal Contact: UINTALANDS ASSOCIATION **Rating:** Approved
CRAIG DAY **Rating Date:** 06/02/2010
Address: 1885 E GENTILE **Activity Status:** Active
LAYTON, UT 84041
Phone Number: 435-544-5297
City Served (Area):
County: SUMMIT COUNTY
System Type: Non-community **Last Inv Update:** 07/18/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 08/10/2010 **Total Dsgn Cap:**
Population: 450 **Surveyor:** JULIE COBLEIGH **Total Emerg Cap:**
Oper Period: 4/15 to 12/1

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office	Emergency	Email Address
AC	DAY, CRAIG		801-544-5297		

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Unmetered	0	180
			180 Total Svc Connections

Storage

Total Storage: 133,000 GAL **Number of Units:** 4 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	ST001	Ground	35,000 GAL	Concrete		A	NO
ST002	ST002	Ground	35,000 GAL	Concrete		A	NO
ST003	ST003	Ground	35,000 GAL	Concrete		A	NO
ST004	ST004	Ground	28,000 GAL	Plastic		A	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	UINTALANDS SPRING HYPOCHLORINATOR		A	

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	PUMP STATION #1 TO-ST001	A		P			
PF002	PUMP STATION #2 TO-UPPERTAN	A		P			

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	UINTALANDS SPRING	Active	SP				Yes	GW	Seasonal	4/15 to 12/1	

**Reports measured flow for wells, approved design capacity for all other sources.*